

Emergency lighting Report

Emergency lighting						
Asset Name	Date of install	Type / comments	Location	Install configuration	Emergency duration hours	Wattage
Em1	2019-10-03	Supply DB2-7	Lounge by sofa	Maintained	3	3
Em2	2019-10-03	Supply DB2/7	Lounge exit	Maintained	3	3
Em3	2019-10-03	Supply from EM test switch	Outside flats 1-2	Maintained	3	3
Em4	2019-10-03	Supply EM test switch	External flats 1-2	Maintained	3	3
Em5	2019-10-03	Supply EM test switch	Outside flat 5	Maintained	3	3
Em6	2019-10-03	Supply Em test switch	Outside flat 17	Maintained	3	3
Em7	2019-10-03	Supply Em test switch	Outside flat 19/20	Maintained	3	3
Em8	2019-10-03	Supply EM switch	Outside flat 21-25	Maintained	3	3
Em9	2019-10-16	Supply EM switch in wardens flat	Guest room	Non-maintained	3	3

Installation of EM lights